



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

October 23, 2024

PERSHING ELEMENTARY SCHOOL

6537 W 37th Street
Berwyn, IL 60402

Project/Site ID: PERSHING ELEMENTARY SCHOOL

DCFS Provider ID:

First Environmental File ID: 24-8687

Date Received: October 08, 2024

Dear :

The samples referenced above were submitted to our laboratory for lead analysis in drinking water in support of the Department of Children and Family Services Policy Guide 2017.13, "Lead Testing of Water in Licensed Day Care Facilities". Details of the samples collected are noted in the following pages and on the enclosed chain of custody form.

The results of the sample analyses are detailed on the following pages. Sample results that begin with a "<" do not contain lead above the reporting limit listed in parts per billion (ppb). Results without a "<" are positive for lead at the concentration listed.

All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number:

1002922024-13: effective 03/06/24 through 02/28/2025.

I thank you for the opportunity to be of service to you. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact us at (630) 778-1200 or firstinfo@firstenv.com. More information can be found at www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water.

Sincerely,

Ryan Gerrick
Project Manager



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: PERSHING ELEMENTARY SCHOOL
Project/Site ID: PERSHING ELEMENTARY SCHOOL
DCFS Provider ID:

Date Received 10/08/24
Date Reported 10/23/24

Total Metals **Method: 200.8R5.4**
Analysis Date: 10/22/24

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
24-8687-001	1 Kitchen 1	FDRW	10/2/2024 5:30	< 2.00
24-8687-002	2 Kitchen 1	FLSH	10/2/2024 5:30	< 2.00
24-8687-003	3 Kitchen 2	FDRW	10/2/2024 5:32	< 2.00
24-8687-004	4 Kitchen 2	FLSH	10/2/2024 5:32	< 2.00
24-8687-005	5 Hydration Station	FDRW	10/2/2024 5:34	< 2.00
24-8687-006	6 Hydration Station	FLSH	10/2/2024 5:34	< 2.00
24-8687-007	7 Fountain Boys 121	FDRW	10/2/2024 5:36	< 2.00
24-8687-008	8 Fountain Boys 121	FLSH	10/2/2024 5:36	< 2.00
24-8687-009	9 Fountain Girls 105	FDRW	10/2/2024 5:38	< 2.00
24-8687-010	10 Fountain Girls 105	FLSH	10/2/2024 5:38	< 2.00
24-8687-011	11 Basement Fountain	FDRW	10/2/2024 5:40	< 2.00
24-8687-012	12 Basement Fountain	FLSH	10/2/2024 5:40	< 2.00
24-8687-013	13 Boys 208B Fountain	FDRW	10/2/2024 5:42	< 2.00
24-8687-014	14 Boys 208B Fountain	FLSH	10/2/2024 5:42	< 2.00
24-8687-015	15 Girls 208B Fountain	FDRW	10/2/2024 5:44	< 2.00
24-8687-016	16 Girls 208B Fountain	FLSH	10/2/2024 5:44	< 2.00
24-8687-017	17 Gym Office Fountain	FDRW	10/2/2024 5:46	< 2.00
24-8687-018	18 Gym Office Fountain	FLSH	10/2/2024 5:46	< 2.00
24-8687-019	19 Nurses Office	FDRW	10/2/2024 5:48	< 2.00
24-8687-020	20 Nurses Office	FLSH	10/2/2024 5:48	< 2.00



Chain of Custody Record for Daycare Facilities

Daycare Facility Information

Daycare Name: Pershing Elementary School
 DCFS Provider ID: _____
 Address: 6537 W 37th Street
 City/State/Zip: Berwyn, IL 60402
 Report Contact: _____
 Contact Phone: 708-303-4024
 Contact email: bsanchez@bsd100.org

Client/Report Information

If these samples were collected by an outside consultant for the school,
 please complete the following fields:

Report to (Company Name): _____
 Report to (Name): _____
 Report to (e-mail): _____
 Report to (phone): _____

Sampling Information

Sampled by: Steve
 Date Faucets Last Used: 10/11
 Time Faucets Last Used: 6pm

Sample Information:

Date Collected	Time Collected	Bottle No.	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
<u>10/2</u>	<u>5:30 AM</u>	<u>1</u>	<u>Kitchen 1</u>	<u>Sink</u>	<u>First Draw</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>001</u>
	<u>5:30</u>	<u>2</u>	<u>Kitchen 1</u>	<u>Sink</u>	<u>Flush</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>002</u>
	<u>0532</u>	<u>3</u>	<u>Kitchen 2</u>	<u>Sink</u>	<u>First Draw</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>003</u>
	<u>↓</u>	<u>4</u>	<u>Kitchen 2</u>	<u>Sink</u>	<u>Flush</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>004</u>
	<u>0534</u>	<u>5</u>	<u>Hydration Station</u>	<u>Sink</u>	<u>First Draw</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>005</u>
	<u>↓</u>	<u>6</u>	<u>Station</u>	<u>Sink</u>	<u>Flush</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>006</u>
	<u>0536</u>	<u>7</u>	<u>Fountain</u>	<u>Sink</u>	<u>First Draw</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>007</u>
	<u>↓</u>	<u>8</u>	<u>Box 121</u>	<u>Sink</u>	<u>Flush</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>008</u>
	<u>0538</u>	<u>9</u>	<u>Fontain</u>	<u>Sink</u>	<u>First Draw</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>009</u>
	<u>↓</u>	<u>10</u>	<u>Girly 105</u>	<u>Sink</u>	<u>Flush</u>	<u>250 mL</u>	<u>Lead 200.8</u>	<u>010</u>

Comments: _____

Total Due \$600

Relinquished By: [Signature]

Date/Time: 10/8/08 152

Received By: _____

N Y

Date/Time: _____

10-8-24 0951

