



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

October 22, 2024

FREEDOM MIDDLE SHOOL

3016 S Ridgeland Ave
Berwyn, IL 60402

Project/Site ID: FREEDOM MIDDLE SHOOL

DCFS Provider ID:

First Environmental File ID: 24-8685

Date Received: October 08, 2024

Dear :

The samples referenced above were submitted to our laboratory for lead analysis in drinking water in support of the Department of Children and Family Services Policy Guide 2017.13, "Lead Testing of Water in Licensed Day Care Facilities". Details of the samples collected are noted in the following pages and on the enclosed chain of custody form.

The results of the sample analyses are detailed on the following pages. Sample results that begin with a "<" do not contain lead above the reporting limit listed in parts per billion (ppb). Results without a "<" are positive for lead at the concentration listed.

All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number:

1002922024-13: effective 03/06/24 through 02/28/2025.

I thank you for the opportunity to be of service to you. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact us at (630) 778-1200 or firstinfo@firstenv.com. More information can be found at www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water.

Sincerely,

Ryan Gerrick
Project Manager



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: FREEDOM MIDDLE SHOOOL
Project/Site ID: FREEDOM MIDDLE SHOOOL
DCFS Provider ID:

Date Received 10/08/24
Date Reported 10/22/24

Total Metals **Method: 200.8R5.4**
Analysis Date: 10/21/24

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
24-8685-001	1 Kitchen 1	FDRW	10/8/2024 6:00	< 2.00
24-8685-002	2 Kitchen 1	FLSH	10/8/2024 6:00	< 2.00
24-8685-003	3 Kitchen 2	FDRW	10/8/2024 6:00	< 2.00
24-8685-004	4 Kitchen 2	FLSH	10/8/2024 6:00	< 2.00
24-8685-005	5 Staff	FDRW	10/8/2024 6:02	< 2.00
24-8685-006	6 Staff	FLSH	10/8/2024 6:02	< 2.00
24-8685-007	7 Lounge	FDRW	10/8/2024 6:04	< 2.00
24-8685-008	8 Lounge	FLSH	10/8/2024 6:04	< 2.00
24-8685-009	9 Ice Maker	FDRW	10/8/2024 6:05	< 2.00
24-8685-010	11 1st Fl Hall MPR	FDRW	10/8/2024 6:07	< 2.00
24-8685-011	12 1st Fl Hall MPR	FLSH	10/8/2024 6:07	< 2.00
24-8685-012	13 Girls Gym	FDRW	10/8/2024 6:09	< 2.00
24-8685-013	14 Girls Gym	FLSH	10/8/2024 6:09	< 2.00
24-8685-014	15 Boys Gym	FDRW	10/8/2024 6:11	< 2.00
24-8685-015	16 Boys Gym	FLSH	10/8/2024 6:11	< 2.00
24-8685-016	17 1st Fl Bottle Filler	FDRW	10/8/2024 6:13	< 2.00
24-8685-017	18 1st Fl Bottle Filler	FLSH	10/8/2024 6:13	< 2.00
24-8685-018	19 2nd Fl Rm 215 Bottle Filler	FDRW	10/8/2024 6:15	< 2.00
24-8685-019	20 2nd Fl Rm 215 Bottle Filler	FLSH	10/8/2024 6:15	< 2.00
24-8685-020	21 2nd Fl Rm 215 Hall	FDRW	10/8/2024 6:17	< 2.00
24-8685-021	22 2nd Fl Rm 215 Hall	FLSH	10/8/2024 6:17	< 2.00
24-8685-022	23 2nd Fl RM 236 Hall	FDRW	10/8/2024 6:18	< 2.00
24-8685-023	24 2nd Fl RM 236 Hall	FLSH	10/8/2024 6:19	< 2.00
24-8685-024	25 3rd Fl Rm 315 Bottle Filler	FDRW	10/8/2024 6:19	< 2.00
24-8685-025	26 3rd Fl Rm 315 Bottle Filler	FLSH	10/8/2024 6:23	< 2.00
24-8685-026	27 3rd Fl Rm 315 Hall	FDRW	10/8/2024 6:23	< 2.00



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: FREEDOM MIDDLE SHOOL
Project/Site ID: FREEDOM MIDDLE SHOOL
DCFS Provider ID:

Date Received 10/08/24

Date Reported 10/22/24

Total Metals **Method: 200.8R5.4**
Analysis Date: 10/21/24

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
24-8685-027	28 3rd Fl Rm 315 Hall	FLSH	10/8/2024 6:25	< 2.00
24-8685-028	29 3rd Fl Rm 304 Hall	FDRW	10/8/2024 6:25	< 2.00
24-8685-029	30 3rd Fl Rm 304 Hall	FLSH	10/8/2024 6:27	< 2.00



Chain of Custody Record for Daycare Facilities

Daycare Facility Information	
Daycare Name:	Freedom Middle School
DCFS Provider ID:	
Address:	3016 S Ridgeland Ave
City/State/Zip:	Berwyn, IL 60402
Report Contact:	
Contact Phone:	708-303-4024
Contact email:	bsanchez@bsd100.org

Client/Report Information	
If these samples were collected by an outside consultant for the school, please complete the following fields:	
Report to (Company Name):	
Report to (Name):	
Report to (e-mail):	N/A
Report to (phone):	

Sampling Information	
Sampled by:	GP/EE
Date Faucets Last Used:	10/7
Time Faucets Last Used:	1:50pm

Sample Information:

Date Collected	Time Collected	Bottle No.	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
10/8	6:00 AM	1	Kitchen 1	Sink	First Draw	250 mL	Lead 200.8	24-7685-001
	6:00	2	Kitchen 1	Sink	Flush	250 mL	Lead 200.8	-002
	6:00	3	Kitchen 2	Sink	First Draw	250 mL	Lead 200.8	-003
	6:00	4	Kitchen 2	Sink	Flush	250 mL	Lead 200.8	-004
	6:02	5	Kitchen 3	Sink	First Draw	250 mL	Lead 200.8	-005
	6:02	6	Kitchen 3	Sink	Flush	250 mL	Lead 200.8	-006
	6:04	7	Refrigerator	Frig Dispenser	First Draw	250 mL	Lead 200.8	-007
	6:04	8	Refrigerator	Frig Dispenser	First Draw	250 mL	Lead 200.8	-008
	6:05	9	Ice Maker	Ice Machine	First Draw	960 mL	Lead 200.8	-009
	6:05	10	Ice Maker	Ice Machine	First Draw	960 mL	Lead 200.8	-010

Comments: Total Due \$ 1028.00 870

Relinquished By: [Signature] Date/Time: 10/8/08 8:50 Received By: [Signature] Date/Time: 10/8/08 9:50
 Filename: C:\Users\Bryel\Desktop\Lead Pb\Daycare Pb\1st DW Lead COC Daycare Reviewed: 08/08/18 by NEC/TD



Chain of Custody Record for Daycare Facilities

Sample Information:

24-8685

Date Collected	Time Collected	Bottle No.	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
10/8	6:07	11	1st FL HALL	Sink	First Draw	250 ml	Lead 200.8	-010
	6:07	12	NPR	Sink	Flush	250 ml	Lead 200.8	-011
	6:09	13	KIT'S	Sink	First Draw	250 ml	Lead 200.8	-012
	6:09	14	gym	Sink	Flush	250 ml	Lead 200.8	-013
	6:11	15	Boys	Sink	First Draw	250 ml	Lead 200.8	-014
	6:11	16	gym	Sink	Flush	250 ml	Lead 200.8	-015
	6:13	17	Bottle Filler	Sink	First Draw	250 ml	Lead 200.8	-016
	6:13	18	1st FL	Sink	Flush	250 ml	Lead 200.8	-017
	6:15	19	Bottle Filler	Sink	First Draw	250 ml	Lead 200.8	-018
	6:15	20	2nd FL R15	Sink	Flush	250 ml	Lead 200.8	-019
	6:17	21	2nd FL HALL	Sink	First Draw	250 ml	Lead 200.8	-020
	6:17	22	215	Sink	Flush	250 ml	Lead 200.8	-021
	6:19	23	2nd FL HALL	Sink	First Draw	250 ml	Lead 200.8	-022
	6:19	24	Rm 836	Sink	Flush	250 ml	Lead 200.8	-023
	6:23	25	Bottle Filler	Sink	First Draw	250 ml	Lead 200.8	-024
	6:23	26	3rd FL 315 HALL	Sink	Flush	250 ml	Lead 200.8	-025
	6:25	27	3rd FL HALL	Sink	First Draw	250 ml	Lead 200.8	-026
	6:25	28	Rm 315	Sink	Flush	250 ml	Lead 200.8	-027
	6:27	29	3rd FL HALL	Sink	First Draw	250 ml	Lead 200.8	-028
	6:27	30	3rd FL HALL	Sink	Flush	250 ml	Lead 200.8	-029
		31		Sink	First Draw	250 ml	Lead 200.8	
		32		Sink	Flush	250 ml	Lead 200.8	
		33		Sink	First Draw	250 ml	Lead 200.8	
		34		Sink	Flush	250 ml	Lead 200.8	

Comments:

Total Due \$1020 + 820

Relinquished By: *[Signature]*

Date/Time: 10/8/18 9:50

Received By: *[Signature]*

Date/Time: 10/8/18 9:50