



**First  
Environmental  
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

October 24, 2024

**EMERSON ELEMENTARY SCHOOL**

6850 W 31st St  
Berwyn, IL 60402

Project/Site ID: EMERSON ELEMENTARY SCHOOL

DCFS Provider ID:

First Environmental File ID: 24-8691

Date Received: October 08, 2024

Dear :

The samples referenced above were submitted to our laboratory for lead analysis in drinking water in support of the Department of Children and Family Services Policy Guide 2017.13, "Lead Testing of Water in Licensed Day Care Facilities". Details of the samples collected are noted in the following pages and on the enclosed chain of custody form.

The results of the sample analyses are detailed on the following pages. Sample results that begin with a "<" do not contain lead above the reporting limit listed in parts per billion (ppb). Results without a "<" are positive for lead at the concentration listed.

All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number:

1002922024-13: effective 03/06/24 through 02/28/2025.

I thank you for the opportunity to be of service to you. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact us at (630) 778-1200 or [firstinfo@firstenv.com](mailto:firstinfo@firstenv.com). More information can be found at [www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water](http://www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water).

Sincerely,

Ryan Gerrick  
Project Manager



**First  
Environmental  
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

**Analytical Report**

**Client:** EMERSON ELEMENTARY SCHOOL  
**Project/Site ID:** EMERSON ELEMENTARY SCHOOL  
**DCFS Provider ID:**

**Date Received** 10/08/24

**Date Reported** 10/24/24

**Total Metals**                      **Method: 200.8R5.4**  
**Analysis Date:** 10/23/24

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
24-8691-001	1 Staff	FDRW	10/7/2024 6:00	< 2.00
24-8691-002	2 Staff	FLSH	10/7/2024 6:00	< 2.00
24-8691-003	3 Gym	FDRW	10/7/2024 6:02	< 2.00
24-8691-004	4 Gym	FLSH	10/7/2024 6:02	< 2.00
24-8691-005	5 First Fl Rm 102	FDRW	10/7/2024 6:04	< 2.00
24-8691-006	6 First Fl Rm 102	FLSH	10/7/2024 6:04	< 2.00
24-8691-007	7 2nd Fl Rm 220	FDRW	10/7/2024 6:06	< 2.00
24-8691-008	8 2nd Fl Rm 220	FLSH	10/7/2024 6:06	< 2.00
24-8691-009	9 Teacher Lounge	FDRW	10/7/2024 6:08	< 2.00
24-8691-010	10 Teacher Lounge	FLSH	10/7/2024 6:08	< 2.00



## Chain of Custody Record for Daycare Facilities

### Daycare Facility Information

Daycare Name: Emerson Elementary School  
 DCFS Provider ID: \_\_\_\_\_  
 Address: 6850 W 31st Street  
 City/State/Zip: Berwyn, IL 60402  
 Report Contact: \_\_\_\_\_  
 Contact Phone: 708-303-4024  
 Contact email: bsanchez@bsd100.org

### Client/Report Information

If these samples were collected by an outside consultant for the school,  
 please complete the following fields:

Report to (Company Name): \_\_\_\_\_  
 Report to (Name): \_\_\_\_\_  
 Report to (e-mail): \_\_\_\_\_  
 Report to (phone): \_\_\_\_\_

### Sampling Information

Sampled by: Stall  
 Date Faucets Last Used: 10/5  
 Time Faucets Last Used: 6 PM

### Sample Information:

Date Collected	Time Collected	Bottle No.	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
10/7	6 AM	1	STAFF Kitchen	Sink	First Draw	250 mL	Lead 200.8	24-8691-001
	6:00	2	Kitchen	Sink	Flush	250 mL	Lead 200.8	-002
	6:02	3	SGYM	Sink	First Draw	250 mL	Lead 200.8	-003
	6:02	4	SGYM	Sink	Flush	250 mL	Lead 200.8	-004
	6:04	5	<del>STAFF</del> 102	Sink	First Draw	250 mL	Lead 200.8	-005
	6:04	6	102	Sink	Flush	250 mL	Lead 200.8	-006
	6:06	7	220 and 2	Sink	First Draw	250 mL	Lead 200.8	-007
	6:06	8	220 and 2	Sink	Flush	250 mL	Lead 200.8	-008
	6:08	9	Teacher Lounge	Sink	First Draw	250 mL	Lead 200.8	-009
	6:08	10	Teacher Lounge	Sink	Flush	250 mL	Lead 200.8	-010

Comments: \_\_\_\_\_

Total Due \$ 420<sup>00</sup> 300

Relinquished By: [Signature]

Date/Time: 10/8/08

Received By: [Signature]

Date/Time: 10/7/08