



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

October 24, 2024

HERITAGE MIDDLE SCHOOL

6850 W 31st Street
Berwyn, IL 60402

Project/Site ID: HERITAGE MIDDLE SCHOOL

DCFS Provider ID:

First Environmental File ID: 24-8689

Date Received: October 08, 2024

Dear :

The samples referenced above were submitted to our laboratory for lead analysis in drinking water in support of the Department of Children and Family Services Policy Guide 2017.13, "Lead Testing of Water in Licensed Day Care Facilities". Details of the samples collected are noted in the following pages and on the enclosed chain of custody form.

The results of the sample analyses are detailed on the following pages. Sample results that begin with a "<" do not contain lead above the reporting limit listed in parts per billion (ppb). Results without a "<" are positive for lead at the concentration listed.

All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number:

1002922024-13: effective 03/06/24 through 02/28/2025.

I thank you for the opportunity to be of service to you. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact us at (630) 778-1200 or firstinfo@firstenv.com. More information can be found at www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water.

Sincerely,

Ryan Gerrick
Project Manager



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: HERITAGE MIDDLE SCHOOL
Project/Site ID: HERITAGE MIDDLE SCHOOL
DCFS Provider ID:

Date Received 10/08/24
Date Reported 10/24/24

Total Metals **Method: 200.8R5.4**
Analysis Date: 10/22/24

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
24-8689-001	1 Kitchen 1	FDRW	10/7/2024 5:30	< 2.00
24-8689-002	2 Kitchen 1	FLSH	10/7/2024 5:30	< 2.00
24-8689-003	3 Nurse	FDRW	10/7/2024 5:32	< 2.00
24-8689-004	4 Nurse	FLSH	10/7/2024 5:32	< 2.00
24-8689-005	5 Staff	FDRW	10/7/2024 5:34	< 2.00
24-8689-006	6 Staff	FLSH	10/7/2024 5:34	< 2.00
24-8689-007	7 Ice Maker	FDRW	10/7/2024 5:35	< 2.00
24-8689-008	8 Boys Gym	FDRW	10/7/2024 5:37	< 2.00
24-8689-009	9 Boys Gym	FLSH	10/7/2024 5:37	< 2.00
24-8689-010	10 Girls Gym	FDRW	10/7/2024 5:38	< 2.00
24-8689-011	11 Girls Gym	FLSH	10/7/2024 5:38	< 2.00
24-8689-012	12 1st Fl Rm 106 (1)	FDRW	10/7/2024 5:40	< 2.00
24-8689-013	13 1st Fl Rm 106 (1)	FLSH	10/7/2024 5:40	< 2.00
24-8689-014	14 1st Fl Rm 106 (2)	FDRW	10/7/2024 5:42	< 2.00
24-8689-015	15 1st Fl Rm 106 (2)	FLSH	10/7/2024 5:42	< 2.00
24-8689-016	16 1st Fl Rm 115 Bottle Filler	FDRW	10/7/2024 5:44	< 2.00
24-8689-017	17 1st Fl Rm 115 Bottle Filler	FLSH	10/7/2024 5:44	< 2.00
24-8689-018	18 1st Fl Rm 115	FDRW	10/7/2024 5:46	< 2.00
24-8689-019	19 1st Fl Rm 115	FLSH	10/7/2024 5:46	< 2.00
24-8689-020	20 2nd Fl Rm 208 (1)	FDRW	10/7/2024 5:48	< 2.00
24-8689-021	21 2nd Fl Rm 208 (1)	FLSH	10/7/2024 5:48	< 2.00
24-8689-022	22 2nd Fl Rm 208 (2)	FDRW	10/7/2024 5:05	< 2.00
24-8689-023	23 2nd Fl Rm 208 (2)	FLSH	10/7/2024 5:05	< 2.00
24-8689-024	24 2nd Fl Rm 211	FDRW	10/7/2024 5:52	< 2.00
24-8689-025	25 2nd Fl Rm 211	FLSH	10/7/2024 5:52	< 2.00
24-8689-026	26 1st Fl Rm 211 Bottle Filler	FDRW	10/7/2024 5:54	< 2.00



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: HERITAGE MIDDLE SCHOOL
Project/Site ID: HERITAGE MIDDLE SCHOOL
DCFS Provider ID:

Date Received 10/08/24
Date Reported 10/24/24

Total Metals **Method: 200.8R5.4**
Analysis Date: 10/23/24

Lab Number	Sample ID and Location Description	Type	Date/Time Collected	Lead Result ug/L (ppb)
24-8689-027	27 1st Fl Rm 211 Bottle Filler	FLSH	10/7/2024 5:54	< 2.00



Chain of Custody Record for Daycare Facilities

Daycare Facility Information

Daycare Name: Heritage Middle School
 DCFS Provider ID: _____
 Address: 6850 W 31st Street
 City/State/Zip: Berwyn, IL 60402
 Report Contact: _____
 Contact Phone: 708-303-4024
 Contact email: bsanchez@bsd100.org

Client/Report Information

If these samples were collected by an outside consultant for the school,
 please complete the following fields:

Report to (Company Name): _____
 Report to (Name): _____
 Report to (e-mail): _____
 Report to (phone): _____

Sampling Information

Sampled by: 52202
 Date Faucets Last Used: 10/16
 Time Faucets Last Used: 1:17 PM

Sample Information:

Date Collected	Time Collected	Bottle No.	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
10/17	5:30 AM	1	Kitchen 1	Sink	First Draw	250 mL	Lead 200.8	24-8689-001
	5:32	2	Kitchen 1	Sink	Flush	250 mL	Lead 200.8	-002
	5:32	3	Kitchen 2	Sink	First Draw	250 mL	Lead 200.8	-003
	5:32	4	Kitchen 2	Sink	Flush	250 mL	Lead 200.8	-004
	5:34	5	Kitchen 3	Sink	First Draw	250 mL	Lead 200.8	-005
	5:34	6	Kitchen 3	Sink	Flush	250 mL	Lead 200.8	-006
	5:35	7	Ice Maker	Ice Machine	First Draw	960 mL	Lead 200.8	-007
	5:37	8	Boys	Sink	First Draw	250 mL	Lead 200.8	-008
	5:37	9	Boys	Sink	Flush	250 mL	Lead 200.8	-009
	5:38	10	Boys	Sink	First Draw	250 mL	Lead 200.8	-010

Comments: _____

Total Due \$ 8200.810

Relinquished By: [Signature]

Date/Time: 10/16/08 9:50

Received By: [Signature]

Date/Time: 10/16/08 9:50



Chain of Custody Record for Daycare Facilities

Sample Information:

Date Collected	Time Collected	Bottle No.	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
10/17	5:38	11	64m	Sink	Flush	250 ml	Lead 200.8	24-8689-011
	5:40	12	1st FL	Sink	First Draw	250 ml	Lead 200.8	-012
	5:40	13	106	Sink	Flush	250 ml	Lead 200.8	-013
	5:42	14	1st FL	Sink	First Draw	250 ml	Lead 200.8	-014
	5:42	15	106	Sink	Flush	250 ml	Lead 200.8	-015
	5:44	16	Bottle 1st 115	Sink	First Draw	250 ml	Lead 200.8	-016
	5:44	17	FILLER	Sink	Flush	250 ml	Lead 200.8	-017
	5:46	18	1st FL	Sink	First Draw	250 ml	Lead 200.8	-018
	5:46	19	115	Sink	Flush	250 ml	Lead 200.8	-019
	5:48	20	2nd FL	Sink	First Draw	250 ml	Lead 200.8	-020
	5:48	21	208	Sink	Flush	250 ml	Lead 200.8	-021
	5:50	22	2nd FL	Sink	First Draw	250 ml	Lead 200.8	-022
	5:51	23	208	Sink	Flush	250 ml	Lead 200.8	-023
	5:52	24	2nd FL	Sink	First Draw	250 ml	Lead 200.8	-024
	5:52	25	211	Sink	Flush	250 ml	Lead 200.8	-025
	5:54	26	2nd FL	Sink	First Draw	250 ml	Lead 200.8	-026
	5:54	27	BOTTLE FILLER	Sink	Flush	250 ml	Lead 200.8	-027
	5:59	28	111	Sink	First Draw	250 ml	Lead 200.8	-028
		29	111	Sink	Flush	250 ml	Lead 200.8	-029

Total Due \$208.16

Comments:

Relinquished By: *[Signature]*

Date/Time: 10/8/09 Received By: *[Signature]*

10/8/09

Date/Time: 9:20