



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

October 23, 2024

KOMENSKY ELEMENTARY SCHOOL

2515 Cuyler Ave
Berwyn, IL 60402

Project/Site ID: KOMENSKY ELEMENTARY SCHOOL

DCFS Provider ID:

First Environmental File ID: 24-8686

Date Received: October 08, 2024

Dear :

The samples referenced above were submitted to our laboratory for lead analysis in drinking water in support of the Department of Children and Family Services Policy Guide 2017.13, "Lead Testing of Water in Licensed Day Care Facilities". Details of the samples collected are noted in the following pages and on the enclosed chain of custody form.

The results of the sample analyses are detailed on the following pages. Sample results that begin with a "<" do not contain lead above the reporting limit listed in parts per billion (ppb). Results without a "<" are positive for lead at the concentration listed.

All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number:

1002922024-13: effective 03/06/24 through 02/28/2025.

I thank you for the opportunity to be of service to you. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact us at (630) 778-1200 or firstinfo@firstenv.com. More information can be found at www.dph.illinois.gov/topics-services/environmental-health-protection/lead-in-water.

Sincerely,

Ryan Gerrick
Project Manager



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: KOMENSKY ELEMENTARY SCHOOL
Project/Site ID: KOMENSKY ELEMENTARY SCHOOL
DCFS Provider ID:

Date Received 10/08/24
Date Reported 10/23/24

Total Metals **Method: 200.8R5.4**
Analysis Date: 10/21/24

| Lab Number | Sample ID and Location Description | Type | Date/Time Collected | Lead Result ug/L (ppb) |
|-------------|------------------------------------|------|---------------------|------------------------|
| 24-8686-001 | 1 Staff 112 | FDRW | 10/4/2024 5:15 | < 2.00 |
| 24-8686-002 | 2 Staff 112 | FLSH | 10/4/2024 5:15 | < 2.00 |
| 24-8686-003 | 3 Room 137 Fountain | FDRW | 10/4/2024 5:17 | < 2.00 |
| 24-8686-004 | 4 Room 137 Fountain | FLSH | 10/4/2024 5:17 | < 2.00 |
| 24-8686-005 | 5 2nd Floor Room 235 Fountain | FDRW | 10/4/2024 5:19 | < 2.00 |
| 24-8686-006 | 6 2nd Floor Room 235 Fountain | FLSH | 10/4/2024 5:19 | < 2.00 |
| 24-8686-007 | 7 2nd Floor Boys Fountain | FDRW | 10/4/2024 5:21 | < 2.00 |
| 24-8686-008 | 8 2nd Floor Boys Fountain | FLSH | 10/4/2024 5:21 | < 2.00 |
| 24-8686-009 | 9 Room 204 Fountain | FDRW | 10/4/2024 5:23 | < 2.00 |
| 24-8686-010 | 10 Room 204 Fountain | FLSH | 10/4/2024 5:23 | < 2.00 |
| 24-8686-011 | 11 Gym | FDRW | 10/4/2024 5:25 | < 2.00 |
| 24-8686-012 | 12 Gym | FLSH | 10/4/2024 5:25 | < 2.00 |
| 24-8686-013 | 13 Nurses Office | FDRW | 10/4/2024 5:27 | < 2.00 |
| 24-8686-014 | 14 Nurses Office | FLSH | 10/4/2024 5:27 | < 2.00 |
| 24-8686-015 | 15 108 Hallway Fountain | FDRW | 10/4/2024 5:29 | < 2.00 |
| 24-8686-016 | 16 108 Hallway Fountain | FLSH | 10/4/2024 5:29 | < 2.00 |
| 24-8686-017 | 17 Room 111 Fountain | FDRW | 10/4/2024 5:31 | 2.55 |
| 24-8686-018 | 18 Room 111 Fountain | FLSH | 10/4/2024 5:31 | 5.18 |
| 24-8686-019 | 19 Boiler Room Fountain | FDRW | 10/4/2024 5:33 | < 2.00 |
| 24-8686-020 | 20 Boiler Room Fountain | FLSH | 10/4/2024 5:33 | < 2.00 |



Chain of Custody Record for Daycare Facilities

Daycare Facility Information

Daycare Name: Kornensky Elementary School

DCFS Provider ID: _____

Address: 2515 Cuyler Ave

City/State/Zip: Berwyn, IL 60402

Report Contact: _____

Contact Phone: 708-303-4024

Contact email: bsanchez@bsd100.org

Client/Report Information

If these samples were collected by an outside consultant for the school,
please complete the following fields:

Report to (Company Name): _____

Report to (Name): AD/A

Report to (e-mail): _____

Report to (phone): _____

Sampling Information

Sampled by: Steve

Date Faucets Last Used: 10/3

Time Faucets Last Used: 6 PM

Sample Information:

| Date Collected | Time Collected | Bottle No. | Sample Location Description | Fixture Type | Sample Type | Sample Volume | Analysis | Lab Sample ID |
|----------------|----------------|------------|-----------------------------|--------------|-------------|---------------|------------|---------------|
| <u>10/4</u> | <u>515 AM</u> | <u>1</u> | <u>STAFF Kitchen 1</u> | Sink | First Draw | 250 ml | Lead 200.8 | <u>001</u> |
| | <u>0515</u> | <u>2</u> | <u>112 Kitchen 1</u> | Sink | Flush | 250 ml | Lead 200.8 | <u>002</u> |
| | <u>0517</u> | <u>3</u> | <u>FOUNTAIN</u> | Sink | First Draw | 250 ml | Lead 200.8 | <u>003</u> |
| | <u>↓</u> | <u>4</u> | <u>10137</u> | Sink | Flush | 250 ml | Lead 200.8 | <u>004</u> |
| | <u>0519</u> | <u>5</u> | <u>FOUNTAIN</u> | Sink | First Draw | 250 ml | Lead 200.8 | <u>005</u> |
| | <u>↓</u> | <u>6</u> | <u>FOUNTAIN</u> | Sink | Flush | 250 ml | Lead 200.8 | <u>006</u> |
| | <u>0521</u> | <u>7</u> | <u>FOUNTAIN</u> | Sink | First Draw | 250 ml | Lead 200.8 | <u>007</u> |
| | <u>↓</u> | <u>8</u> | <u>FOUNTAIN</u> | Sink | Flush | 250 ml | Lead 200.8 | <u>008</u> |
| | <u>0522</u> | <u>9</u> | <u>FOUNTAIN</u> | Sink | First Draw | 250 ml | Lead 200.8 | <u>009</u> |
| | <u>↓</u> | <u>10</u> | <u>FOUNTAIN</u> | Sink | Flush | 250 ml | Lead 200.8 | <u>010</u> |

Comments: Total Due \$600

Relinquished By: [Signature] Date/Time: 10/8/14 0950

Received By: NY Date/Time: 10/8/14 0950

Filename: C:\Users\B-Rye\Desktop\Lead Pb\Daycare Pb\1st DW Lead COC Daycare Reviewed: 08/08/18 by NEC/TD

24-810810

